

1. ALL SITE LIGHTING SHALL BE CONTROLLED BY TIME CLOCK. REFER TO EL2.1.B COLUMN LINE 13/E FOR LOCATION.
2. BURIAL DEPTH OF CONDUITS UNDER PAVEMENT SHALL BE 24" BELOW GRADE MINIMUM. BURIAL DEPTH OF CONDUITS IN GRASS AREA SHALL BE 18" BELOW GRADE MINIMUM.
3. ALL BRANCH CIRCUIT WIRING FOR SITE LIGHTING SHALL BE #6 COPPER IN 1" CONDUIT MINIMUM UNLESS OTHERWISE NOTED. CIRCUITING SHOWN ACCOMMODATED VOLTAGE DROP FOR #6 WIRE. BURIAL DEPTH OF CONDUITS UNDER PAVEMENT SHALL BE 24" BELOW GRADE MINIMUM. BURIAL DEPTH OF CONDUITS IN GRASS AREA SHALL BE 18" BELOW GRADE MINIMUM.



Plot Date:

J446-101-W- ES2.0.2.E1